

**ADDENDUM NO. 002
TO
BIDDING AND CONTRACT DOCUMENTS
HANCOCK COUNTY PORT AND HARBOR COMMISSION
STENNIS INTERNATIONAL AIRPORT

NEW HANGAR BUILDING REDESIGN
MDEQ-18-00036 RESTORE GRANT**

TO: ALL PLANHOLDERS
DATE: September 5, 2019

This Addendum forms a part of the Bidding and Contract Documents and modifies the original documents as noted below. **Acknowledge receipt of this Addendum in the space provided in DIVISION 00 – MISCELLANEOUS DOCUMENTS, SECTION 003000 - FORM OF PROPOSAL (Page 003000- PG 2).** Failure to do so may subject a Bidder to disqualification.

This Addendum consists of **Two (2) pages**.

PROJECT MANUAL:

No Updates to this section.

SPECIFICATIONS:

No Updates to this section.

RESPONSE TO CONTRACTOR QUESTIONS:

- 1). *The definition of “Unfinished” shall be defined as having no flooring, no ceilings, no light fixtures, no plumbing fixtures, no toilet room accessories, no drywall installed on the inside of the room except for those walls required to be fire rated. No painting.*
All plumbing shall be stubbed up ready for future installation of plumbing fixtures. No blocking for any accessories. Floor drain shall be installed. Door leading into the rooms shall be installed with all hardware .
- 2). *The contractor shall use the square footage for the building that he/she derives from the building layout provided in the architectural plans.*
- 3). *The contractor shall provide a metal roof system that will carry a 20-year warranty as required by the specifications. Disregard the previous to utilize a PBR panel and instead use a double locking seam roof panel that will meet a 20-year warranty.*

This concludes **Addendum No. 002** in its entirety. If you have any questions, please direct them to the Engineer, Michael Baker International, Inc, at (228) 818-2839 from the hours of 8:00 am until 5:00 pm, Monday - Friday, prior to the bid opening date of **September 10, 2019**

Questions received less than 48 hours prior to the date of the Bid opening may not be answered. Please reference "Instructions to bidders", for additional information.

NOTE: ***This Addendum has been transmitted to prospective Bidders and all Plan-holders via MPTAP, www.mbakерplanroom.com and e-mail***